

### 1 Features

- 3-axis accelerometer
- User selectable  $\pm 2$  or  $\pm 6g$  range
- User selectable sample rate of 10, 20, 40, 80, and 160 Hertz
- 12-bit and 16-bit resolution
- User selectable deadband and trigger
- Accurate time stamped data using Real Time Clock (RTC) with power back-up
- Convenient on/off button
- Data recorded to a removable microSD card (1GB included)
- Easily readable comma separated text data files
- Data transfer compatible with Windows or Linux via Universal Serial Bus (USB) interface (no special software)
- System appears as USB Mass Storage Device to Windows and Linux OS's.
- Standard replaceable "AA" type battery
- LED indicator lights for system status
- Weighs 2oz (55g) with alkaline battery

### 2 Applications

The X6-1A is applicable to:

- Continuous time stamped shock and motion monitoring of critical freight.
- Monitoring human motor activity, or actigraphy, such as exercise intensity or sleeping disorders.
- Automotive performance monitoring
- Educational purposes

### 3 Description

The USB Accelerometer X6-1A uses a low noise digital accelerometer sensor, precise time stamped data logging, microSD memory storage, real-time data access and USB connectivity. Acceleration is collected in X, Y, and Z axes and stored at a user selectable rate of up to 160hz. When connected via the USB to a personal computer, the X6-1A appears as a standard mass storage device containing the comma delimited data files and user setup files. The commercial standard "AA" battery provides extended life operation suitable to long term data acquisition applications.



Figure 1: USB Accelerometer X6-1A

### 3.1 Operating Instructions

The X6-1A is a simple, economical solution to capture continuous motion data and quickly deliver the information for analysis. The following instructions outline the steps to begin using the X6-1A. Configuration settings and mounting methods will depend on the particular application.

- Step 1: Disassemble the enclosure by unscrewing the #6 machine screw. Place a AA type battery into the battery holder with the positive battery terminal facing away from the USB connector. Reassemble the enclosure.
- Step 2: Plug the X6-1A into a computer and allow the computer operating system register the device as a Mass Storage Device.
- Step 3: Configure the X6-1A by editing the appropriate tags in the config.txt file located in the root directory of the microSD card. Choose faster sample rates to capture rapidly changing events. Use high gain 16-bit modes to monitor very small motion or vibration. Refer to section 3.2.4 for a complete list of configuration options.
- Step 4: If necessary, initialize the RTC clock by creating a time.txt file (see section 3.2.6). Setting the RTC ensures that recorded data can be correlated to absolute time.
- Step 5: Unplug the X6-1A from the USB port and firmly attach the system to the target object. Depending on the g-force intensity expected, tape, tie-wraps, pipe clamps, or glue are suitable methods of attachment. The 0.75" #6-32 screw can be replaced with a longer screw to firmly attach the X6-1A enclosure to the target object.
- Step 6: Press the button located at the rear of the enclosure to initiate data recording, (see Figure 2). The red LED will blink as the configuration file is accessed. If the time.txt file is present, the RTC is initialized with the time written in the file. Then, the blue LED will begin to blink at a 1 second interval indicating the system is operating. The red LED will blink periodically as data is written to the microSD card.
- Step 7: To stop recording, press and hold the on/off button for about 3 seconds. The LEDs will blink rapidly for 2 seconds and then turn off. Release the button and the X6-1A turns off. Data recording is restarted by pressing the button again (see Step 6).




Figure 2: Starting the X6-1A

**3.2 Electrical**

**3.2.1 Sensor**

**Table 1: Accelerometer Sensor Characteristics**

Parameter	Condition	Min	Typical	Max	Units
Acceleration range	High Gain	±1.8	±2.0		g
	Low Gain	±5.6	±6.0		g
12-bit Resolution	High Gain (±2g)		0.001		g/count
	Low Gain (±6g)		0.003		g/count
16-bit Resolution	High Gain (±2g)		0.00006		g/count
	Low Gain (±6g)		0.00020		g/count
Linearity	X,Y axis		±2		%FS
	Z axis		±3		%FS
Zero-g Offset Level Accuracy	High Gain (±2g) X, Y axis	-0.002		0.002	g
	High Gain (±2g) Z axis	-0.004		0.004	g
	Low Gain (±6g) X, Y axis	-0.004		0.004	g
	Low Gain (±6g) Z axis	-0.006		0.006	g



**Figure 3: Accelerometer Sensor Orientation**

### 3.2.2 Indicator LEDs

System status is indicated by the two LEDs located near the USB connector. The blue LED indicates system operation. A steady blinking blue LED, once per second, indicates a properly operating system. The red LED blinks when data is written or read from the microSD memory card. In data logging mode, the period at which the red LED blinks depends on the sample rate and other configuration settings. The red LED will also blink with USB Human Interface Device (HID) communication activity when connected to a PC. The “statusindicators” tag in the system configuration file turns off or changes the brightness of the LED status indicators (see section 3.2.4.14).

### 3.2.3 Battery

#### 3.2.3.1 Main Battery

The X6-1A is powered by a single “AA” sized battery. Gulf Coast Data Concepts recommends an alkaline battery (ANSI type 15A or IEC type LR6) or lithium battery (ANSI type 15L or IEC FR6) to operate the X6-1A. A lithium (Li/FeS<sub>2</sub>) battery provides approximately 30% more capacity than an alkaline battery. Typical operation times using an alkaline battery range from 3 to 7 days depending on system configuration, battery quality, and microSD card type. The battery is not used when the system is connected to a computer USB port. A 5v supply via the USB connector provides extended operation of the device independent of the AA battery. Common USB power adapters or USB battery packs for consumer electronics can provide the required 5v supply. See section 3.2.4.15 for more details.

#### 3.2.3.2 RTC Power Backup

The Real Time Clock (RTC) maintains the current time using the AA battery, the USB power, or a secondary backup capacitor if the AA battery or USB power are not present. The backup capacitor will operate the RTC for about 12 hours depending on its charge state. The backup capacitor charges using the AA battery or the USB power. Allow several minutes for the capacitor to charge after it has been depleted.

### 3.2.4 System Configuration Options

The X6-1A is configured using a set of tags and settings stored in a text file named “config.txt”, which is located in the root directory of the microSD card. The system reads the configuration file at boot time. Table 2 lists the configuration file tags. A tag is followed by an equal sign (“=”) and an applicable tag setting. A line finishes with a newline character or carriage return character. Tags are not case sensitive. Tab and space characters are ignored. Lines starting with a semicolon (“;”) are treated as comments and ignored by the system. The system will use the default settings listed in Table 2 if the config.txt file is not found.

**Table 2: Configuration File Tags and Descriptions**

Tag	Valid Settings	Default	Description
16bitres	-	Off	Sets device to record data at 16-bit resolution
deadband	An integer between 0 and 32767	0	Sets the deadband to a range expressed in “counts”. A new sample is recorded if any sensor axis exceeds the previous recorded reading by the deadband value
deadbandtimeout	An integer between 0 and 65535	3	Specifies the period in seconds when a sample is recorded regardless of the deadband setting. This feature ensures periodic data is recorded during very long periods of inactivity.
dwel	An integer between 0 and 65535	1	The number of samples recorded after a deadband threshold triggered event
gain	“high” and “low”	low	High gain sets the system to record +/-2g, low gain records +/-6g
hpf	0, 24, 25, 26, 27	Holds previous setting	Implements a high-pass filter, 0 turns the filter off
microres	-	Off	The presence of this tag sets the device to record time stamps with 0.1ms effective precision.
rebootondisconnect	-	off on disconnect	The presence of this tag causes the system to start recording after disconnect from a USB port.
rtcclcktrim	An integer between -127 and 128	0	Fine adjustment for RTC correction
samplesperfile	An integer greater than 0	28896	The number of lines of data per data file before a new file is created
samplerate	10, 20, 40, 80, 160	40	Sets the rate at which data is collected and recorded to the microSD card.
starttime and stoptime	See section 3.2.4.12	-	Defines when to start and stop recording
stoponvusb	-	Off	Stops data logging if 5v USB power is present (see section 3.2.4.13)
statusindicators	“Normal”, “High”, “Off”	Normal	LED status indicators can be activated with normal brightness (Normal), activated with high brightness (High), or completely deactivated (Off).
timeoutonusb	-	Off	Stops USB if no host communications detected (see section 3.2.4.15)

**3.2.4.1 16bitres**


Add “16bitres” on a single line in the configuration file and the X6-1A records acceleration data at 16-bit resolution. The default mode is 12-bit resolution. Section 3.2.5 describes how to convert the 12-bit or 16-bit data format into units of g (standard acceleration of gravity).

**3.2.4.2 deadband**

“deadband” defines the minimum difference between recorded sensor readings. A new sample from the accelerometer sensor must exceed the previous recorded reading before the microcontroller records the data. The deadband setting is expressed in "counts" units and is applied to the output of each axis. Table 3 lists the equations necessary to convert a desired g threshold to deadband counts. The deadband value can be set to an integer between 0 and 32767. The deadband function is an effective way to reduce the amount of data collected and extend the system battery life. The deadband functions as a event threshold limit when used in conjunction with the “dwell” feature.

**Table 3: Deadband Calculation**

AD Resolution	Gain Setting	Deadband Counts
12-bit	Low	340×g
	High	1024×g
16-bit	Low	5440×g
	High	16384×g



**Figure 4: Graphical Illustration of the Deadband Feature**

### 3.2.4.3 deadbandtimeout

“deadbandtimeout” defines the period in seconds when a sample is recorded by the device regardless of the deadband setting. This feature ensures periodic data is recorded during extended periods of inactivity. A valid setting for the deadbandtimeout is an integer between 0 and 65535.

### 3.2.4.4 dwell

The “dwell” tag defines the number of consecutive samples recorded at the set sample rate after a deadband threshold event. The deadband threshold event occurs when a sensor reading exceeds the last recorded value by the deadband setting. A valid dwell setting is an integer between 0 and 65535.




Figure 5: Graphical Illustration of the Dwell Feature

### 3.2.4.5 gain

“gain” defines the sensor scale. “high” sets the system to record at  $\pm 2g$ . “low” sets the system to record at  $\pm 6g$ .

### 3.2.4.6 hpf

A high-pass filter is implemented using the “hpf” tag with one of five possible settings. The -3dB lower cutoff frequency is defined in Hertz by the HPF tag and the sample rate, as listed in Table 4.

**Table 4: HPF -3dB Cutoff Frequencies (Hz)**

Tag Setting	Sample Rate (Hz)				
	10	20	40	80	160
hpf = 0	Turns high pass filter off				
hpf = 24	0.0031	0.0062	0.0124	0.0248	0.0497
hpf = 25	0.0016	0.0031	0.0062	0.0124	0.0248
hpf = 26	0.0008	0.0016	0.0031	0.0062	0.0124
hpf = 27	0.0004	0.0008	0.0016	0.0031	0.0062

**3.2.4.7 microres**

The “microres” option sets the device to record time stamps with 0.1ms precision. In micro-resolution mode, the time stamps are recorded as XX.YYYYYZZ where XX are seconds, YYYY are 0.1 milliseconds, and ZZ are spurious digits that should be ignored. The micro-resolution option must be implemented at sample rates of 80 and 160 hertz to provide the best timing precision. The power saving features of the X6-1A are disabled in micro-resolution mode and battery life is shortened accordingly.

**3.2.4.8 rebootondisconnect**

The X6-1A incorporates an on/off button for initiating and terminating the data recording process. Data recording is automatically started upon disconnect from a computer USB port if the tag word “rebootondisconnect” is included in the configuration file. Note that the system must first be turned on and the configuration file read before the rebootondisconnect option is implemented by the system. Subsequent disconnects will then cause a reboot and immediate data recording.

**3.2.4.9 rtclocktrim**

The “rtcclcocktrim” setting adjusts the RTC oscillator frequency. Positive values increase the oscillation period (lower frequency) and negative values decrease the oscillation period (higher frequency). A valid setting is an integer between -127 and 128. By default, the RTC provides +/- 2ppm (parts per million) precision between 0°C and 40°C. This feature should be used by advanced users only.

**3.2.4.10 samplesperfile**

“samplesperfile” defines the number of data lines each file can have before a new file is created. This tag controls the size of the data files into easily manageable lengths for later processing. This setting is loaded as a signed 32-bit integer, which can translate into very large data files. The user should exercise caution before setting large files and test the end-user application for data limitations.

### 3.2.4.11 samplerate

The “samplerate” tag defines the interval that data is recorded in Hertz, or samples per second. Valid sample rate settings are 10, 20, 40, 80, and 160 Hz. At 80 and 160 Hz, the configuration file should also include the “microres” tag to provide the best timing precision (see section 3.2.4.7).

### 3.2.4.12 starttime and stoptime

The X6-1A starts and stops data recording based on the times defined using the “starttime” and “stoptime” tags. The times must be in “MM HH” 24-hr format with the two entries separated by a space. Entries marked with “\*” operate as a wild card. The stop time is 5 seconds after the start time unless defined otherwise by the stoptime tag. Example timing configurations:

**Example 1:** Start recording at 12:30pm and stop recording at 6:00pm.

```
starttime = 30 12  
stoptime = 00 18
```

**Example 2:** Start recording at the beginning of every hour and stop recording at the 45 minutes later.

```
starttime = 00 *  
stoptime = 45 *
```

### 3.2.4.13 stoponvusb

The “stoponvusb” tag stops data logging operations when a 5v supply is detected on the USB connector. By default, the device switches power from the internal battery to the USB 5v and continues to log data.

### 3.2.4.14 statusindicators

The brightness intensity of the LED status indicators is defined using the “statusindicators” tag and valid settings of “normal”, “high”, and “off”.

### 3.2.4.15 timeoutonusb

The “timeoutonusb” tag returns the microprocessor to normal operating speed if no USB communications are detected within 7 seconds after connection to a USB port. This reduces the power requirements when operated from an external 5v USB supply. By default, the microprocessor continues at high-speed mode waiting for USB communications. Utilize the timeoutonusb feature when operating the device from an external 5v USB battery pack.

## 3.2.4.16 Example Configuration Files

Example A) The following configuration records data constantly at 20 hertz in low gain mode (+/-6g). The device will boot and begin logging data once removed from a computer USB port. Each data file is 30,000 lines long or about 25 minutes.

```
; example X6-1A config file
; set range to +/-6g
gain = low
; set to record constantly at 20 hertz
samplerate = 20
deadband = 0
; set file length
samplesperfile = 30000
; make device start upon USB disconnect
rebootondisconnect
```

**Figure 6: Configuration File Example A**

Example B) Setting the deadband to 51 counts at high gain causes the device to record only changes greater than 0.05g. The deadbandtimeout setting forces a sample write every 60 seconds. Status indicators will turn off about 10 seconds after the device turns on.

```
; example X6-1A config file
; set range to +/-2g
gain = high
; set to 40 hertz
samplerate = 40
; record motion > 0.05g
deadband = 51
; force a write every minute
deadbandtimeout = 60
; set file length
samplesperfile = 30000
;turn off LEDs
statusindicators = off
; make device start upon USB disconnect
rebootondisconnect
```

**Figure 7: Configuration File Example B**

Example C) The micro-resolution is activated to provide the best timing precision at the 80 Hz sample rate. The sensor is set to high gain and 16-bit resolution. If motion exceeds 1638 counts (0.1g), the device captures continuous data 80 times a second for 2 seconds or until the change in acceleration falls below 0.1g. The timeoutonusb option reduces the system power requirements while connected an external 5v USB battery pack.

```
; example X6-1A config file
; set range to +/-2g, 16-bit res
gain = high
16bitres
; set to 80 hertz
samplerate = 80
; turn on microresolution timing
microres
; set threshold > 0.1g
; record 2 seconds of data
deadband = 1638
dwell = 160
; force a write every 5 minutes
deadbandtimeout = 300
; set file length
samplesperfile = 30000
; using external 5v USB battery
timeoutonusb
```

**Figure 8: Configuration File Example C**

**3.2.5 Data Files**

Data is written to files in comma separated text format starting with the file header information and followed by data entries. The header describes the system configuration, firmware version, and the precise time when the file was created. Each header line is preceded with a semicolon (“;”). Table 6 lists the valid header tags. Data entries include a time stamp and the raw accelerometer sensor readings from the X, Y, and Z axes. The time stamp is seconds elapsed from the start time recorded in the header. The raw sensor data format is signed digital “counts”. Table 5 lists the equations for converting the counts data into g (standard acceleration of gravity).

The X6-1A creates a new data file when the system is booted or when the maximum number of data lines is reached in the previous data file. A system boot condition occurs when the on/off button is pressed, 5v power is restored to the system via the USB connector, or when the X6-1A is removed from a computer USB port with the “rebootondisconnect” feature enabled. Data files are placed in a folder named “GCDC” and are named data-XXX.csv, where XXX is a sequential number starting with 001. The system will create up to 999 files. At the beginning of each file, a header is written describing the system configuration, firmware version, and the precise time when the file was created. Figure 9 represents an example data file.

The last line of the final data file records the reason for the termination, such as “shutdown: switched off”, “shutdown: low battery”, “shutdown: max files exceeded”, “shutdown: vbus disconnect”, or “connected to computer”. The line is designated as a comment with a semicolon (“;”).

```

;Title, http://www.gcdataconcepts.com, X6-1a
;Version, 1000, Build num, 0x97B, Build date, 20101014 12:47:12, SN:CCDC22010050607
;Start_time, 2010-10-28, 00:32:35.447
;Switch, Unknown
;Temperature, 28.00, deg C, Vbat, 1470, mv
;Gain, high
;SampleRate, 40,Hz
;Deadband, 51, counts
;DeadbandTimeout, 60,sec
;Headers, time, Ax, Ay, Az
1.587,-201,-620,512
1.612,-118,-638,376
1.637,-208,-619,-569
1.662,-453,166,1090
1.687,-462,-173,1975
1.713,-370,-52,2047
1.738,-551,-611,2030
1.762,-404,-673,-622
1.788,-38,-476,535
1.813,-144,-677,-466
1.837,-378,124,295
1.863,-501,87,2047
1.888,-610,-477,2047
    
```

**Figure 9: Example Data File**

**Table 5: Converting Raw Counts Data to g Units**

AD Resolution	Gain Setting	g
12-bit	Low	counts / 340
	High	counts / 1024
16-bit	Low	counts / 5440
	High	counts / 16384

**Table 6: Data File Header Tags**

<b>Tag</b>	<b>Description</b>
16 bit resolution	Signifies the data format as 16-bit
Deadband	A new sample from the sensor must exceed the last reading by the deadband value
DeadbandTimeout	The period in seconds when a sample is recorded regardless of the deadband setting
Dwell	The number of samples recorded after a threshold event
Gain	“high” or “low” indicating the system gain setting
Headers	The names of each column of data in the file
HPF filter set to:	The high pass filter value
SampleRate	Rate at which data is recorded to the microSD card
Start Time	The current time when the data file was created
Temperature	Temperature of sensor in °C when data file was created
Title	The name of the USB Accelerometer X6-1A unit
Vbat	Battery voltage measured at the start time
Version	The version control information of the firmware, including unique serial number

### **3.2.6 Real Time Clock**

A real time clock (RTC) is integrated into the X6-1A and is used to determine time for each line of data recorded. Initializing the RTC ensures that the start time and individual time stamps can be correlated to an absolute time. An uninitialized or reset RTC defaults to the first day of the year 1900.

The RTC is set using a text file named “time.txt” located in the root directory of the microSD card. The system looks for the time.txt file upon booting. If the file exists, the time stored in the file is loaded to the RTC and the time.txt file is deleted. The time information in the time.txt file must be in the exact “yyyy-MM-dd HH:mm:ss” 24-hour format, occur on the first line, and end with a newline character. The time file method of setting the RTC does not require special communication drivers so it can be implemented using any text editor. Direct initialization of the RTC is possible but requires specific device drivers from Gulf Coast Data Concepts.

The RTC maintains ±2ppm accuracy (0°C to +40°C) and is backed up by a separate power system when the AA battery is not present or when the device is not attached to USB power (see section 3.2.3.2). The RTC operates for about 12 hours using the backup power. The RTC also provides the system temperature (°C) recorded to the header of each data file.

### **3.2.7 Memory Card**

The X6-1A stores data to a removable microSD flash memory card. The system is compatible with microSD and microSDHC cards and logging performance improves with faster cards. A new memory card must be formatted to FAT16 for proper operation of the X6-1A, which limits the maximum memory space to 2GB. Under Windows XP, the card must be formatted using the “FAT” file system and the default allocation size. The X6-1A will create a folder called “GCDC”, if not already present, to place the data files (see section 3.2.5). The “config.txt” and “time.txt” files must occur in the root directory (see section 3.2.4 and section 3.2.6). The X6-1A functions as a Mass Storage Device to computer operating systems when transferring data to and from the microSD memory card.

## 3.3 Mechanical

The X6-1A electronics are enclosed in a three-part semi-transparent blue plastic enclosure. The top and bottom enclosure components and the printed circuit board are secured together with a 0.75" long #6-32 screw and nut. Longer screw lengths can facilitate attachment of the X6-1A to other structures. A slip-on cap protects the USB connector. The X6-1A weighs 2oz (55g) with an alkaline battery.

### 3.3.1 Dimensions




Figure 10: Enclosure Dimensions

### 3.3.2 Assembly




Figure 11: Exploded View of USB Accelerometer X6-1A

### 4 Software

The X6-1A records data to comma delimited text files and uses text based files for configuration settings. Therefore, no special software is required to utilize the X6-1A. However, Gulf Coast Data Concepts provides the Java based software program *XMLR8R* that allows easy visual presentation of the data, copy-paste export of data segments, as well as configuration file and time file creation utilities. *XMLR8R* is included on the microSD card of each X6-1A unit or can be downloaded from the website at [www.gcdataconcepts.com](http://www.gcdataconcepts.com). For data analysis, Gulf Coast Data Concepts recommends using a commercial or open source mathematics package, such as MatLab, Mathcad, Microsoft Excel, OpenOffice Calc, Octave, R, or similar applications.